



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 07/17/2013
Received: 07/15/2013
Sampled By: John Orolin
Work Order: 3196006

C Renaissance Water LLC
L Attn: John Orolin
I 20705 Willamette Dr
E West Linn OR, 97068
N Phone: (503) 908-1734
T

Project: Certification
Project # : N/A
PWSID # : -
PO # : 7-15-13

Sampling Location: Kitchen Sink
Sample Matrix: Water

Lab Number **Sample Name** **Sampled: 7/15/13 9:00** **Sample Composition:**
3196006-01 **Sample #1 West Linn Tap Water**

Wet Chemistry	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
Alkalinity, Total (CaCO ₃)	1067	EPA 310.1	mg/L	36	2	-	-	07/16/13 11:26
Chlorine, Total	1012	EPA 330.5	mg/L	0.7	0.1	-	-	07/15/13 11:00
Specific Conductance (EC)	1064	EPA 120.1	uS/cm	89.5	1	-	-	07/15/13 09:40
Dissolved Oxygen		EPA 360.1	mg/L	9.2	2.0	-	-	07/15/13 11:00
pH	1925	EPA 150.1	pH Units	7.1		-	8.5	07/15/13 10:55 R
Total Dissolved Solids	1930	EPA 120.1	mg/L	45	1	-	500	07/15/13 09:40

Lab Number **Sample Name** **Sampled: 7/15/13 9:00** **Sample Composition:**
3196006-02 **Sample #2 Nimbus 5-Stage R.O.**

Wet Chemistry	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
Alkalinity, Total (CaCO ₃)	1067	EPA 310.1	mg/L	3	2	-	-	07/16/13 11:26
Chlorine, Total	1012	EPA 330.5	mg/L	ND	0.1	-	-	07/15/13 11:00
Specific Conductance (EC)	1064	EPA 120.1	uS/cm	3.18	1	-	-	07/15/13 09:40
Dissolved Oxygen		EPA 360.1	mg/L	9.4	2.0	-	-	07/15/13 11:00
pH	1925	EPA 150.1	pH Units	5.8		-	8.5	07/15/13 10:57 R
Total Dissolved Solids	1930	EPA 120.1	mg/L	2	1	-	500	07/15/13 09:40