AME	NDMENT OF SOLICITATION	1. CONTRACT ID Co	ODE PAGE OF PAGES			
2. AMENDME	NT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE	REQUISITION NUMBER	5. PROJECT NUMBER (If applicable)	
00004		05/015/2019			P/N 8617883	
6. ISSUED BY	CODE		7. ADMINISTERED BY (If other than Item 6) CODE			
1240 E9th	U CLEVELAND Street, Room 2179 , Ohio 44199		Same as #6.			
O NAME AND	ADDRESS OF CONTRACTOR (Mumber etro	not county State and 710 Co	1/2)	V)	NIT OF OOL IOITATION NUMBER	
o. NAWE AND	) ADDRESS OF CONTRACTOR (Number, stre	set, county, State and 217 Co		70Z08319R 9B. DATED (SEI 04/18/2019	E ITEM 11) TION OF CONTRACT/ORDER NUMBER	
CODE		CILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
(a) By completi or (c) By separ RECEIVED AT by virtue of this communication	knowledge receipt of this amendment prior to to to to gitems 8 and 15, and returning	copies of the amendmen cludes a reference to the soli IPT OF OFFERS PRIOR TO eady submitted, such change mendment, and is received pr	t; (b) By acknowledging receip citation and amendment numb THE HOUR AND DATE SPEC may be made by letter or elec	t of this amendment or ers. FAILURE OF YO IFIED MAY RESULT I tronic communication,	n each copy of the offer submitted; UR ACKNOWLEDGMENT TO BE IN REJECTION OF YOUR OFFER. If	
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PUR NUMBER IN ITEM 10A.		R NUMBER AS DESCR			
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
	D. OTHER (Specify type of modification and	authority)				
E. IMPORT	ANT: Contractor is not is	required to sign this d	ocument and return	copies	s to the issuing office.	
Request Fo	rion of amendment/modification ( <i>orga</i> or Proposal 70Z08319RPBA0030 RE, MARYLAND., U. S. Coast Gi	00; CPOP REPAIR V	WEST WHARF, U.S. (	COAST GUARD	YARD BALTIMORE,	
1. Acknowl	edgment of Request For Informa	ation responses date	d 05/15/2019.			
	ded herein, all terms and conditions of the doc		or 10A, as heretofore changed			
			James E. Dinda		To a contract of	
15B. CONTRACTOR/OFFEROR 15C. DATE SIGNED			16B. UNITED STATES OF AN	MERICA	16C. DATE SIGNED	
(Si	ignature of person authorized to sign)		(Signature o	f Contracting Officer)	7/12/1	

Previous edition unusable

RREQUEST FOR PROPOSAL 70Z08319RPBA00300; CPOP REPAIR WEST WHARF, U.S. COAST GUARD YARD BALTIMORE, BALTIMORE, MARYLAND., Request For Information Responses A00004 5/15/19

The following answers are requested in order to assure that we are all bidding on the same quantities.

QUESTION: There are 38 piles and caps that need repairs. How much of the pile should be figured to be replaced knowing that each pile/cap may differ in deterioration? Ref.: 01 11 00 par 1.1

<u>ANSWER:</u> Section 01 11 00 1.0 States: Remove and replace existing deteriorated timber decking, repair piles and pile caps (approx. 38), repair damaged pile caps and dislocated timbers shown on drawing C/03. Each pile repair shall be wrapped with a Carbon Wrap system. All pile cap repairs shall use marine grade shims and fasteners. There is no pile replacement, only repairs.

<u>QUESTION:</u> Square feet of existing deck planks to be replaced? Dwg. C-3 states to replace all existing deck planks. REF: 01 11 00 3.0a

ANSWER: 3.0 NEW WORK states any deteriorated deck timbers not all of them (38). Pile to pile cap repairs. Drawing C/03 says all existing DAMAGED not all decking. It can be estimated that deteriorated 6"x12"12' timbers will be found in the areas of the sink holes (shadowed areas C/02-03). Every area on C/03 is indicated with number and description.

<u>QUESTION</u>: The specs request that the contractor coordinate with other useg contractors installing different utilities on the same contruction site. How much time and at what phase of the contract should time be set aside for the in house contractors to perform their work? Ref: 01 11 16 par. 1.0

<u>ANSWER:</u> We will keep everyone out of the work zone except for an emergency repair that may arise outside of the contract.

<u>QUESTION:</u> Quantity of decking to be replaced, so all bidders are bidding the same quantities

ANSWER: 38 Pile to Cap connection repairs, 6"x12"x12' timber deck replacement is 125 timbers.

QUESTION: Length of the pile repairs

ANSWER: Three Feet in length.

QUESTION: Shoring for existing concrete utilities Vaults?? What are they sitting on?

ANSWER: Utilities sit mostly in the existing soil

RREQUEST FOR PROPOSAL 70Z08319RPBA00300; CPOP REPAIR WEST WHARF, U.S. COAST GUARD YARD BALTIMORE, BALTIMORE, MARYLAND., Request For Information Responses A00004 5/15/19

**QUESTION:** Do pile repair match that of Pier 1 Q&A?

ANSWER: Very similar, refer to 3.1 REPAIR TYPES

01 11 00 SCOPE OF WORK, Item 1.1- the final sentence in that paragraph states "A final location drawing must be turned in to the USCG".

<u>QUESTION:</u> What level of horizontal and vertical accuracy is required for the map: Sub-centimeter?, Sub-foot?

<u>ANSWER:</u> Utilities must be marked using color coded spray for construction purposes only. Elevations are not needed and horizontal accuracy is only relevant to surrounding landmarks.

<u>QUESTION:</u> Do we have to be on a specific horizontal and vertical control? If so, will that be provided or specified?

ANSWER: No

<u>QUESTION:</u> What is required on the location drawing? Contours, spot grades, utilities, north arrow, bollards etc.? Please specify.

<u>ANSWER:</u> The location drawing is to show all utilities as marked by the GPR service. This drawing must be either color-coded or utilities shown by line type in black and white. A north arrow must be shown. No contours or elevations are needed, but all relative land are needed. Fire hydrants, road edges, hotel location, etc.

<u>QUESTION:</u> Does this need to be signed/sealed by a Maryland Professional Land Surveyor?

ANSWER: No

QUESTION: Does the USCG require an AutoCadd drawing?

ANSWER: No

QUESTION: How many prints are required?7.01 11 16 Work By Others 1.1, 1.2 & 1.3 Please specify what other USCG, Utility Companies or Service Companies will require access to the site.

ANSWER: 3 Copies, Only in an emergency situation outside the scope of work.

RREQUEST FOR PROPOSAL 70Z08319RPBA00300; CPOP REPAIR WEST WHARF, U.S. COAST GUARD YARD BALTIMORE, BALTIMORE, MARYLAND., Request For Information Responses A00004 5/15/19

**QUESTION:** How are the Utilities to be permanently marked?

ANSWER: To be marked as stated in answer #1 answer

<u>QUESTION:</u> Are we required to have a Design Professional inspect the Erosion and Sediment Control after installation? NICET certified and what level?

ANSWER: No, only USCG inspector and or Maryland Dept. of Environment (MDE).

\*\*\*\* New Requests for Information will no longer be accepted.