


Soil Resistivity Worksheet

Location	Spacing (Test Depth)					
	1.52 m(5 ft.)	3 m(10 ft.)	6.1 m(20 ft.)	9.1 m(30 ft.)	12.2 m(40 ft.)	
Meter Readings (steps 2 through 5)						
1 of 5						
2 of 5						
3 of 5						
4 of 5						
5 of 5						
Soil Resistivity Calculations (step 10)						
$\rho = 191.5 \times A \times R$ $\rho =$ soil resistivity in Ω -cm $A =$ Distance between test rods (in feet) $R =$ Resistance obtained from tester			OR	$\rho = 628 \times A \times R$ $\rho =$ soil resistivity in Ω -cm $A =$ Distance between test rods (in metres) $R =$ Resistance obtained from tester		
1 of 5	$\rho =$	$\rho =$	$\rho =$	$\rho =$	$\rho =$	
2 of 5	$\rho =$	$\rho =$	$\rho =$	$\rho =$	$\rho =$	
3 of 5	$\rho =$	$\rho =$	$\rho =$	$\rho =$	$\rho =$	
4 of 5	$\rho =$	$\rho =$	$\rho =$	$\rho =$	$\rho =$	
5 of 5	$\rho =$	$\rho =$	$\rho =$	$\rho =$	$\rho =$	
Test completed by:			Notes:			
Date:						
Client / Project:						
Site Location/ID:						
Ground Resistance Tester Model: _____						
S/N: _____						
Calibration date: _____						
Soil Description:						
Ambient Conditions Temperature: _____						
Present conditions (dry, rain, snow): _____						
Date of last precipitation: _____						

SITE NAME: _____

4 POINT WENNER METHOD
TESTING LAYOUT

- Test Direction 1
- Test Direction 2
- Test Direction 3
- Test Direction 4
- Test Direction 5



Technical Evaluation and
Development Services, LLC
(T.E.D.S.)
tsummers@tedswireless.com
(303) 903-6347

ORGANIZATION NAME
SITE NAME
State

PROJECT NO:
DESIGN OFFICE:
DESIGNED BY: Ted Summers
DRAWN BY: Ted Summers
CHK'D BY:
DATE: 03/07/2020
APPROVED BY:

SITE NAME: _____

SOIL RESISTIVITY NOMOGRAPH

Single Electrode Ground Resistance (R)

___ Ω

Value From Worksheet $\rho = (\Omega\text{-cm})$





___ $\Omega\text{-cm}$

Depth of Grounding Electrode

___ feet



Grounding Electrode Diameter

___ - Inches



Typical 10 ft Ground Rod in 30-in. Deep Trench = 12.5 ft.

Typical Ground Rod 3/4 in. Diameter 10 ft. Long




Technical Evaluation and Development Services, LLC
(T.E.D.S.)
tsummers@tedswireless.com
(303) 903-6347

ORGANIZATION NAME
SITE NAME
State

PROJECT NO:	APPROVED
DESIGN OFFICE: Ted Summers	DATE
DESIGNED BY: Ted Summers	DESCRIPTION
DRAWN BY: Ted Summers	MARK
CHK'D BY:	APPROVED BY:
DATE: 05/07/2020	

SITE NAME

GROUNDING ELECTRODE SYSTEM RESISTANCE



Technical Evaluation and
Development Services, LLC
(T.E.D.S.)
tsummers@tedswireless.com
(303) 903-6347

ORGANIZATION NAME
SITE NAME
State

GROUNDING ELECTRODE SYSTEM DESIGN

Single Rod Ground Resistance (from Nomograph) = (R) 37 Ω

Depth of Ground Rods (from Nomograph) = (D) 20 ft.

Diameter of Ground Rods (from Nomograph) 3/4 in.

Ground Rod Qty (X) 8 ea.

Ground Rod Length <Rod Length> = (L) 10 ft.

Distance Between Rods (d) 20 ft.

Ground Rod Spacing (S) 2L

Combined Resistance Percentage = (Y) 17 %
Y = The point on the graph where X intersects L (Horizontal Line)

Combined Resistance of Proposed
Grounding Electrode System = CR
(CR = R x Y)


37 Ω x 0.17 = 6.29 Ω

Instructions:

- 1) Draw a vertical line on **Number of Rods (X)** in graph.
- 2) Determine diagonal line for **Rod Spacing (S)** based on distance between rods by dividing the Distance between rods (d) by the rod length (L) <S = (d / L)> (1L) 1 rod length, (2L) 2 rod lengths (3L) 3 rod lengths (4L) 4 rod lengths
- 3) At the intersection of the vertical **Number of Rods (X)** line and the diagonal **Rod Spacing (S)** line, draw a horizontal line to the **Combined Resistance (CR)** axis at left.

Note: The point where the horizontal line crosses the **Combined Resistance (R)** axis is the **Percentage (Y)** to use in the calculations to determine the **Combined Resistance (CR)** resistance of the grounding electrode system.


- 4) Multiply the **Single Rod Ground Resistance (R)** times the **Combined Resistance Percentage (Y)** to obtain the **Combined Resistance (CR)** of the grounding electrode system.




PROJECT NO:
DESIGN OFFICE: Ted Summers
DESIGNED BY: Ted Summers
DRAWN BY: Ted Summers
CHK'D BY:
DATE: 03/07/2020

SITE NAME

GROUNDING ELECTRODE SYSTEM DESIGN WITH RADIALS



- ① Typical Ground Rod
 $\frac{3}{4}$ in. Diameter 10 ft. Long
 $15 \text{ Rods: } 256.6\Omega \times 0.095 = 24.4 \Omega$
- ①B Concrete Encased Electrode Bonded to Ground Ring
- ⑤ #2 AWG, Bare, Solid, Tinned Copper Grounding Conductor
- ⑦ Shelter Ground Ring #2 AWG, Bare, Solid, Tinned Copper Grounding Conductor



Technical Evaluation and Development Services, LLC
 (T.E.D.S.)
summers@tedswireless.com
 (303) 903-6347

ORGANIZATION NAME
SITE NAME
 State

PROJECT NO:	MARK	DESCRIPTION	DATE	APPROVED
DESIGN OFFICE: Ted Summers				
DESIGNED BY: Ted Summers				
DRAWN BY: Ted Summers				
CHK'D BY:				
APPROVED BY:				
DATE: 03/07/2020				

NEWPORT RANGER STATION





SOIL RESISTIVITY NOMOGRAPH

Single Electrode Ground Resistance
37 Ω



Value From Worksheet $p=$ (Ω-cm)
13,200 Ω-cm

Depth of Grounding Electrode
12.5 feet

Grounding Electrode Diameter
3/4"



13,200



Technical Evaluation and Development Services, LLC
(T.E.D.S.)
tsummers@tedswireless.com
(303) 903-6347

ORGANIZATION NAME
SITE NAME
State

PROJECT NO.:	DATE:
DESIGN OFFICE:	APPROVED:
DESIGNED BY: Ted Summers	DATE:
DRAWN BY: Ted Summers	DESCRIPTION:
CHK'D BY:	MARK:
APPROVED BY:	DATE:
DATE: 03/07/2020	

NEWPORT RANGER STATION

GROUNDING ELECTRODE SYSTEM RESISTANCE

GROUNDING ELECTRODE SYSTEM DESIGN

Single Rod Ground Resistance (from Nomograph) = (R) 37 Ω

Depth of Ground Rods (from Nomograph) = (D) 20 ft.

Diameter of Ground Rods (from Nomograph) 3/4 in.

Ground Rod Qty (X) 8 ea.

Ground Rod Length <Rod Length> = (L) 10 ft.

Distance Between Rods (d) 20 ft.

Ground Rod Spacing (S) 2L

Combined Resistance Percentage = (Y) 17 %
 Y = The point on the graph where X intersects L (Horizontal Line)

Combined Resistance of Proposed
Grounding Electrode System = CR

(CR = R x Y)



37 Ω x 0.17 = 6.29 Ω

Instructions:

- 1) Draw a vertical line on **Number of Rods (X)** in graph.
- 2) Determine diagonal line for **Rod Spacing (S)** based on distance between rods by dividing the Distance between rods (d) by the rod length (L) $S = (d / L)$
(1L) 1 rod length, (2L) 2 rod lengths (3L) 3 rod lengths (4L) 4 rod lengths
- 3) At the intersection of the vertical **Number of Rods (X)** line and the diagonal **Rod Spacing (S)** line, draw a horizontal line to the **Combined Resistance (CR)** axis at left.

Note: The point where the horizontal line crosses the **Combined Resistance (R)** axis is the **Percentage (Y)** to use in the calculations to determine the **Combined Resistance (CR)** resistance of the grounding electrode system.

- 4) Multiply the **Single Rod Ground Resistance (R)** times the **Combined Resistance Percentage (Y)** to obtain the **Combined Resistance (CR)** of the grounding electrode system.




Technical Evaluation and
Development Services, LLC
(T.E.D.S.)
tsummers@tedswireless.com
(303) 903-6347

ORGANIZATION NAME
SITE NAME
State

PROJECT NO:
DESIGN OFFICE:
DESIGNED BY: Ted Summers
DRAWN BY: Ted Summers
CHK'D BY:
DATE: 03/07/2020

Fall-of-Potential Ground Resistance Field Report

Date of Test: 09/15/2019
Radio Facility Name: Fox Mountain
Conditions: Dry, 52 Degrees
Facility Type: Remote Radio Facility
Resistance Requirement: 10 or 25 Ohms



Test Company: Technical Evaluation and Development Services (T.E.D.S. LLC)

Test Instrument Manufacturer: Extech **Tester Name:** Ted Sumners

Test Instrument Model: GRT300 **Calibration Date:** 2/1/2019

Serial Number: 1804667

Test Configuration: Z- Probe set 60 ft. from grounding system


Test Procedure: Slope Method (Intersecting Curves)

Y-Probe moved in 20% increments to obtain values R₁, R₂ and R₃
 Calculations made to obtain True Resistance Distance

TESTING RESULTS – PASSED or Failed at 27 Ohms

μ	D_P/D_C	μ	D_P/D_C	μ	D_P/D_C
0.40	0.643	0.83	0.575	1.26	0.477
0.41	0.642	0.84	0.573	1.27	0.474
0.42	0.640	0.85	0.571	1.28	0.471
0.43	0.639	0.86	0.569	1.29	0.468
0.44	0.637	0.87	0.567	1.30	0.465
0.45	0.636	0.88	0.566	1.31	0.462
0.46	0.635	0.89	0.564	1.32	0.458
0.47	0.633	0.90	0.562	1.33	0.455
0.48	0.632	0.91	0.560	1.34	0.452
0.49	0.630	0.92	0.558	1.35	0.448
0.50	0.629	0.93	0.556	1.36	0.445
0.51	0.627	0.94	0.554	1.37	0.441
0.52	0.626	0.95	0.552	1.38	0.438
0.53	0.624	0.96	0.550	1.39	0.434
0.54	0.623	0.97	0.548	1.40	0.431
0.55	0.621	0.98	0.546	1.41	0.427
0.56	0.620	0.99	0.544	1.42	0.423
0.57	0.618	1.00	0.542	1.43	0.418
0.58	0.617	1.01	0.539	1.44	0.414
0.59	0.615	1.02	0.537	1.45	0.410
0.60	0.614	1.03	0.535	1.46	0.406
0.61	0.612	1.04	0.533	1.47	0.401
0.62	0.610	1.05	0.531	1.48	0.397
0.63	0.609	1.06	0.528	1.49	0.393
0.64	0.607	1.07	0.526	1.50	0.389
0.65	0.606	1.08	0.524	1.51	0.384
0.66	0.604	1.09	0.522	1.52	0.379
0.67	0.602	1.10	0.519	1.53	0.374
0.68	0.601	1.11	0.517	1.54	0.369
0.69	0.599	1.12	0.514	1.55	0.364
0.70	0.597	1.13	0.512	1.56	0.358
0.71	0.596	1.14	0.509	1.57	0.352
0.72	0.594	1.15	0.507	1.58	0.347
0.73	0.592	1.16	0.504	1.59	0.341
0.74	0.591	1.17	0.502	1.60	0.338
0.75	0.589	1.18	0.499	1.61	0.335
0.76	0.587	1.19	0.497	1.62	0.331
0.77	0.585	1.20	0.494	1.63	0.328
0.78	0.584	1.21	0.491	1.64	0.325
0.79	0.582	1.22	0.488	1.65	0.322
0.80	0.580	1.23	0.486	1.66	0.319
0.81	0.579	1.24	0.483	1.67	0.316
0.82	0.577	1.25	0.480	1.68	0.313

Reading	Distance to Y Probe (ft.)	Measurement Ohms	$\frac{R_3 - R_2}{R_2 - R_1} = u$	D_P/D_C from Table	Distance to Z Probe (ft.) (DZ)	True Resistance Distance (ft.) = (u x DZ)	True Resistance (Ohms)
R ₁	30	27	0.58	0.617	50	31	27 Ohms
R ₂	20	20.3					
R ₃	10	16.4					



Certification:

I certify the results depicted on this form regarding grounding system testing and resulting calculations to be accurate and true.

Name: Ted Sumners

Signature:

Date: 09/15/2019