

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT**



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 08-60-00141
Name of Facility: Lakeside of Charlotte County Condo (Pool)
Address: 25275 Rampart Boulevard
City, Zip: Pt Charlotte 33983

**Correct By: None
Re-Inspection Date: None**

Type: Public Pool > 25000 Gallons
Owner: LAKESIDE OF CHARLOTTE COUNTY CONDOMINIUM ASSOCIATION, INC.
Person In Charge: Binder, Brenda - 1st Choice Co Phone: (941) 625-2255
Pool Operator: Cain, Richard Phone: 941-625-2255

Inspection Information

Purpose: Routine
Inspection Date: 1/30/2018

Begin Time: 11:30 AM
End Time: 12:10 PM

Additional Information

22. Free Chlorine 3.0	VOLUME 28080
23. pH 7.4	POOL LOAD 17
24. Chlor. Stabilizer 0	FLOW RATE 87
33. Flowmeter 80GPM	NIGHT SWIM No
34. Thermometer 87°F	FILTER TYPE CP

Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.

Violation Markings

<p>POOL AREA</p> <p>1. Water Clarity/Algae Control</p> <p>2. Deck/Walkways</p> <p>3. Tile/Pool Finish</p> <p>4. Depth Markers-FBC</p> <p>5. Handrail/Ladder-FBC</p> <p>6. Step Markings-FBC</p> <p>7. Suction Outlets-514.0315(1)</p> <p>8. Gutter Grates/Skimmer-FBC</p> <p>9. Lighting</p> <p>10. No Dive Markings-FBC</p> <p>11. Diving Board-FBC</p> <p>12. Pool Cover</p> <p>13. Pool Side Shower-FBC</p> <p>POOL SAFETY</p> <p>14. Life Hook(s) w/Pole</p> <p>15. Life Ring(s) w/Rope</p> <p>16. Safety Line</p>	<p>17. Rules Posted</p> <p>18. Certification</p> <p>SANITARY FACILITIES</p> <p>19. Supplies 64E-10, FAC</p> <p>20. Clean 64E-10, FAC</p> <p>WATER QUALITY</p> <p>21. Approved Test Kit</p> <p>22. Free Chlor./Brom.</p> <p>23. pH</p> <p>24. Chlor. Stabilizer</p> <p>25. Spa Requirements-ORP</p> <p>EQUIPMENT ROOM</p> <p>26. Wading Pool-Quick Dump</p> <p>27. Water Level/Control</p> <p>28. Disinfection Feeder/Generator</p> <p>29. pH Feeder</p> <p>30. Chem. Container Label-FBC</p> <p>31. Filter / Pump</p>	<p>32. Vacuum Cleaner-FBC</p> <p>33. Flowmeter</p> <p>34. Thermometer</p> <p>35. Pressure/Vacuum Gauge</p> <p>36. Equip. Room</p> <p>37. Cross Connection</p> <p>38. Gas Chlorine Eq.-FBC</p> <p>39. Waste Water - FBC</p> <p>40. D.E. Separator-FBC</p> <p>41. Other Equipment</p> <p>42. Equip. Change-FBC</p> <p>43. Approved Chemicals</p> <p>44. Maintenance Log</p> <p>45. Inspection Posted</p> <p>46. Safety-514.0315(2)</p> <p>47. Fences/Gates- FBC</p> <p>48. Other</p> <p>49. Other</p>
--	--	---

NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

Client Signature:

Sent by email

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



2 of 2

General Comments

Satisfactory

Total Alkalinity =80 ppm

All items are ok
2 CP filters
Collection tank ok
2 stenner feeders
2 pumps (3 hp+3.45hp)

Email Address(es): admin@1stchoicecondo.com;
rich@1stchoicecondo.com

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

Violations Comments

No Violation Comments Available

Inspection Conducted By: Gynal Saintilien (30596)
Inspector Contact Number: Work: (941) 624-7200 ex. 7381
Print Client Name:
Date: 1/30/2018

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Sent by email