

# LINCOLN PSD

WV3302205

## Consumer Confidence Report – 2021 Covering Calendar Year – 2020

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call BRENDA ESCUE at 304-756-2141.

Your water comes from :

Source Name	Source Water Type
INTAKE-COAL RIVER	Surface Water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 3772 and is required to test a minimum of 4 samples per month in accordance with the Total Coliform Rule for

microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

### Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2020 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2020. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

### Terms & Abbreviations

**Maximum Contaminant Level Goal (MCLG):** the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Secondary Maximum Contaminant Level (SMCL):** recommended level for a contaminant that is not regulated and has no MCL.

**Action Level (AL):** the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

**Treatment Technique (TT):** a required process intended to reduce levels of a contaminant in drinking water.

**Maximum Residual Disinfectant Level (MRDL):** the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Non-Detects (ND):** lab analysis indicates that the contaminant is not present.

**Parts per Million (ppm)** or milligrams per liter (mg/l)

**Parts per Billion (ppb)** or micrograms per liter (µg/l)

**Picocuries per Liter (pCi/L):** a measure of the radioactivity in water.

**Millirems per Year (mrem/yr):** measure of radiation absorbed by the body.

**Monitoring Period Average (MPA):** An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

**Nephelometric Turbidity Unit (NTU):** a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

**Running Annual Average (RAA):** an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

**Locational Running Annual Average (LRAA):** Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

### Testing Results for: LINCOLN PSD

The following are results of parameters tested with detections from 2020 samples or from our most recent sampling period since some parameters are on a frequency less than every year by rule:

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2020				

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	11/9/2020	0.0574	0.0417 - 0.0574	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	11/9/2020	2.1	0 - 2.1	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
FLUORIDE	11/9/2020	0.66	0.48 - 0.66	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	11/9/2020	0.2	0.2	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRITE	11/9/2020	0.09	0.09	ppm	1	1	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SELENIUM	11/9/2020	0.92	0 - 0.92	ppb	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	GILCHRIST BOOSTER STATION	2020	27	14.9 - 22.1	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	MOSTELLER RESIDENCE	2020	28	22 - 30.4	ppb	60	0	By-product of drinking water disinfection
TTHM	GILCHRIST BOOSTER STATION	2020	56	7 - 24.7	ppb	80	0	By-product of drinking water chlorination
TTHM	MAXIMUM RESIDENCE TI	2020	7	7.2 - 7.2	ppb	80	0	By-product of drinking water chlorination
TTHM	MOSTELLER RESIDENCE	2020	52	6.8 - 53.7	ppb	80	0	By-product of drinking water chlorination

Chlorine/Chloramines	MPA	MPA Units	RAA	RAA Units
Maximum Disinfection Level				
09/01/2020 - 09/30/2020	2	MG/L	1.6	MG/L



Lead and Copper	Monitoring Period	90 <sup>th</sup> Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2019	0.0255	0 - 0.0479	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2019	0.72	0 - 2.3	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Total Organic Carbon Lowest Month for Removal	Collection Date	Highest Value	Range	Unit	TT	Typical Source
CARBON, TOTAL	12/7/2020	1.3	1 - 1.3	MG/L	0	Naturally present in the environment

Radiological Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
GROSS ALPHA, EXCL. RADON & U	12/16/2019	-0.177	-0.177	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	12/16/2019	0.467	0.467	pCi/L	5	0	Erosion of natural deposits

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	11/9/2020	295	295	MG/L	10000
CARBON, TOTAL	12/7/2020	1.3	1 - 1.3	ppm	10000
NICKEL	11/9/2020	0.0016	0 - 0.0016	MG/L	0.1
SODIUM	11/9/2020	129	38 - 129	MG/L	1000
SULFATE	11/9/2020	187	162 - 187	MG/L	250

During the 2020 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
10/1/2020	CONSUMER CONFIDENCE RULE	CCR ADEQUACY/AVAILABILITY/CONTENT
7/1/2020	CONSUMER CONFIDENCE RULE	CCR REPORT
12/1/2020 - 12/31/2020	DBP STAGE 1	CHLORINE RESIDUAL INADEQUATE
7/1/2020 - 7/31/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
8/1/2020 - 8/31/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR

9/1/2020 - 9/30/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
11/1/2020 - 11/30/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
10/1/2020	LEAD & COPPER RULE	FOLLOW-UP OR ROUTINE TAP M/R (LCR)
1/1/2020 - 3/31/2020	CARBON, TOTAL	INADEQUATE DBP PRECURSOR REMOVAL
7/1/2020 - 9/30/2020	CARBON, TOTAL	INADEQUATE DBP PRECURSOR REMOVAL
1/1/2020	LEAD & COPPER RULE	LEAD CONSUMER NOTICE (LCR)
2/29/2020 - 5/31/2020	HALOACETIC ACIDS	MONITORING, ROUTINE (DBP), MAJOR
2/29/2020 - 5/31/2020	TRIHALOMETHANES	MONITORING, ROUTINE (DBP), MAJOR
4/1/2020 - 6/30/2020	CARBON, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
4/1/2020 - 6/30/2020	ALKALINITY, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	HALOACETIC ACIDS	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	TRIHALOMETHANES	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	CARBON, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	ALKALINITY, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	CARBON, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
10/1/2020 - 12/31/2020	CARBON, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
10/1/2020 - 12/31/2020	ALKALINITY, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
10/1/2020 - 12/31/2020	CARBON, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 7/31/2020	TURBIDITY	MONITORING, ROUTINE (IESWTR/LT1), MAJOR
8/1/2020 - 8/31/2020	TURBIDITY	MONITORING, ROUTINE (IESWTR/LT1), MAJOR
9/1/2020 - 9/30/2020	TURBIDITY	MONITORING, ROUTINE (IESWTR/LT1), MAJOR
11/1/2020 - 11/30/2020	TURBIDITY	MONITORING, ROUTINE (IESWTR/LT1), MAJOR
1/1/2020 - 1/31/2020	TURBIDITY	MONITORING, ROUTINE (IESWTR/LT1), MINOR
1/1/2020 - 12/31/2020	MERCURY	MONITORING, ROUTINE MAJOR
7/1/2020 - 7/31/2020	CHLORINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)
8/1/2020 - 8/31/2020	CHLORINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)
9/1/2020 - 9/30/2020	CHLORINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)
11/1/2020 - 11/30/2020	CHLORINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)
5/15/2020	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION
11/15/2020	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION

Additional Required Health Effects Language:

Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.



Additional Required Health Effects Violation Notices:

Total organic carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts (DBPs). These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increase risk of getting cancer.

There are no additional required health effects violation notices.

There are no additional required health effects notices.

This Consumer Confidence Report is not being mailed to each customer. A copy can be provided upon request by calling our office at 304-756-2141.

## LINCOLN PSD - ROUTE 3

WV3302207

### Consumer Confidence Report – 2021 Covering Calendar Year – 2020

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call BRENDA ESCUE at 304-756-2141.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided above. Your water comes from :

Buyer Name	Seller Name
LINCOLN PSD - ROUTE 3	WVAWC-KANAWHA VALLEY DIST

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

**Radioactive contaminants**, which can be naturally occurring or the result of mining activity.

**Organic contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 2087 and is required to test a minimum of 2 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

#### Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2020 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2020. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

#### Terms & Abbreviations

**Maximum Contaminant Level Goal (MCLG):** the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Secondary Maximum Contaminant Level (SMCL):** recommended level for a contaminant that is not regulated and has no MCL.

**Action Level (AL):** the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

**Treatment Technique (TT):** a required process intended to reduce levels of a contaminant in drinking water.

**Maximum Residual Disinfectant Level (MRDL):** the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Non-Detects (ND):** lab analysis indicates that the contaminant is not present.

**Parts per Million (ppm)** or milligrams per liter (mg/l)

**Parts per Billion (ppb)** or micrograms per liter (µg/l)

**Picocuries per Liter (pCi/L):** a measure of the radioactivity in water.

**Millirems per Year (mrem/yr):** measure of radiation absorbed by the body.

**Monitoring Period Average (MPA):** An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

**Nephelometric Turbidity Unit (NTU):** a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

**Running Annual Average (RAA):** an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

**Locational Running Annual Average (LRAA):** Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.



### Testing Results for: LINCOLN PSD - ROUTE 3

The following are results of parameters tested with detections from 2020 samples or from our most recent sampling period during the past five years since some parameters are on a frequency less than every year by rule:

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2020				

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2020							

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	TOM CALDWELL BOOSTER	2020	34	14.8 - 48.1	ppb	60	0	By-product of drinking water disinfection
TTHM	TOM CALDWELL BOOSTER	2020	59	7.1 - 66.7	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 <sup>th</sup> Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2019	0.0782	0.0019 - 0.1	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2019	1.1	0 - 1.6	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Chlorine/Chloramines	MPA	MPA Units	RAA	RAA Units
Maximum Disinfection Level				
04/01/2020 - 04/30/2020	2.3	MG/L	1.7	MG/L

During the 2020 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
10/1/2020	CONSUMER CONFIDENCE RULE	CCR ADEQUACY/AVAILABILITY/CONTENT
7/1/2020	CONSUMER CONFIDENCE RULE	CCR REPORT
7/1/2020 - 7/31/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR

8/1/2020 - 8/31/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
9/1/2020 - 9/30/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
10/1/2020	LEAD & COPPER RULE	FOLLOW-UP OR ROUTINE TAP M/R (LCR)
1/1/2020	LEAD & COPPER RULE	LEAD CONSUMER NOTICE (LCR)
2/29/2020 - 5/31/2020	HALOACETIC ACIDS	MONITORING, ROUTINE (DBP), MAJOR
2/29/2020 - 5/31/2020	TRIHALOMETHANES	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	CHLORINE	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	HALOACETIC ACIDS	MONITORING, ROUTINE (DBP), MAJOR
7/1/2020 - 9/30/2020	TRIHALOMETHANES	MONITORING, ROUTINE (DBP), MAJOR
8/1/2020 - 8/31/2020	E. COLI	MONITORING, ROUTINE, MINOR (RTCR)
8/1/2020 - 8/31/2020	CHLORINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)
11/15/2020	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION

There are no additional required health effects notices.

There are no additional required health effects violation notices.

All of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants which we are not required to test for which were detected during the 2020 calendar year, or from the most recent testing results from the last five years for parameters tested less often than yearly, from the water system that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
FLUORIDE	2/3/2020	WVAWC-KANAWHA VALLEY DIST	0.8	0.8	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
GROSS ALPHA, EXCL. RADON & U	7/13/2020	WVAWC-KANAWHA VALLEY DIST	1.3	1.3	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	7/13/2020	WVAWC-KANAWHA VALLEY DIST	0	0	pCi/L	5	0	Erosion of natural deposits
NITRATE	4/6/2020	WVAWC-KANAWHA VALLEY DIST	0.25	0.25	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	4/6/2020	WVAWC-KANAWHA VALLEY DIST	0.25	0.25	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits



Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALUMINUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	0.02	0.02	MG/L	0.05
CALCIUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	12	12	MG/L	
CARBON, TOTAL	7/6/2020	WVAWC-KANAWHA VALLEY DIST	1.1	0.9 - 1.1	ppm	10000
CHLORIDE	2/3/2020	WVAWC-KANAWHA VALLEY DIST	7.1	7.1	MG/L	250
MAGNESIUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	6	6	MG/L	
SODIUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	6.2	6.2	MG/L	1000
SULFATE	2/3/2020	WVAWC-KANAWHA VALLEY DIST	36.2	36.2	MG/L	250
ZINC	2/3/2020	WVAWC-KANAWHA VALLEY DIST	0.064	0.064	MG/L	5

During the 2020 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2020				

There are no additional required health effects violation notices.

There are no additional required health effects notices.

This Consumer Confidence Report is not being mailed to each customer. A copy can be provided upon request by calling our office at 304-756-2141.

# LINCOLN PSD - LOWER MUD RIVER WV3302208

## Consumer Confidence Report – 2021 Covering Calendar Year – 2020

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call BRENDA ESCUE at 304-756-2141.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided above. Your water comes from :

Buyer Name	Seller Name
LINCOLN PSD - LOWER MUD RIVER	WVAWC-KANAWHA VALLEY DIST

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 49 and is required to test a minimum of 1 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

### Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2020 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2020. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

### Terms & Abbreviations

**Maximum Contaminant Level Goal (MCLG):** the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Secondary Maximum Contaminant Level (SMCL):** recommended level for a contaminant that is not regulated and has no MCL.

**Action Level (AL):** the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

**Treatment Technique (TT):** a required process intended to reduce levels of a contaminant in drinking water.

**Maximum Residual Disinfectant Level (MRDL):** the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Non-Detects (ND):** lab analysis indicates that the contaminant is not present.

**Parts per Million (ppm)** or milligrams per liter (mg/l)

**Parts per Billion (ppb)** or micrograms per liter (µg/l)

**Picocuries per Liter (pCi/L):** a measure of the radioactivity in water.

**Millirems per Year (mrem/yr):** measure of radiation absorbed by the body.

**Monitoring Period Average (MPA):** An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

**Nephelometric Turbidity Unit (NTU):** a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

**Running Annual Average (RAA):** an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

**Locational Running Annual Average (LRAA):** Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.



### Testing Results for: LINCOLN PSD - LOWER MUD RIVER

The following are results of parameters tested with detections from 2020 samples or from our most recent sampling period during the past five years since some parameters are on a frequency less than every year by rule:

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2020				

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2020							

Disinfection Byproducts	Sample Point	Monitoring Date	Highest LRAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	BOOSTER STA	11/9/2020	48.2	48.2	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	WOODALL RES	11/9/2020	4.3	4.3	ppb	60	0	By-product of drinking water disinfection
TTHM	BOOSTER STA	11/9/2020	76.2	76.2	ppb	80	0	By-product of drinking water chlorination
TTHM	WOODALL RES	11/9/2020	133	133	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 <sup>th</sup> Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2020	0.0016	0.00049 - 0.68	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2019	0	0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Chlorine/Chloramines	MPA	MPA Units	RAA	RAA Units
Maximum Disinfection Level				
04/01/2020 - 04/30/2020	2.1	MG/L	1.1	MG/L

During the 2020 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
10/1/2020	CONSUMER CONFIDENCE RULE	CCR ADEQUACY/AVAILABILITY/CONTENT
7/1/2020	CONSUMER CONFIDENCE RULE	CCR REPORT
7/1/2020 - 7/31/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
8/1/2020 - 8/31/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
9/1/2020 - 9/30/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
11/1/2020 - 11/30/2020	CHLORINE	FAILURE TO COMPLETE OR SUBMIT MOR
11/15/2020	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION

There are no additional required health effects notices.

There are no additional required health effects violation notices.

All of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants which we are not required to test for which were detected during the 2020 calendar year, or from the most recent testing results from the last five years for parameters tested less often than yearly, from the water system that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
FLUORIDE	2/3/2020	WVAWC-KANAWHA VALLEY DIST	0.8	0.8	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
GROSS ALPHA, EXCL. RADON & U	7/13/2020	WVAWC-KANAWHA VALLEY DIST	1.3	1.3	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	7/13/2020	WVAWC-KANAWHA VALLEY DIST	0	0	pCi/L	5	0	Erosion of natural deposits
NITRATE	4/6/2020	WVAWC-KANAWHA VALLEY DIST	0.25	0.25	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	4/6/2020	WVAWC-KANAWHA VALLEY DIST	0.25	0.25	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits



Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALUMINUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	0.02	0.02	MG/L	0.05
CALCIUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	12	12	MG/L	
CARBON, TOTAL	7/6/2020	WVAWC-KANAWHA VALLEY DIST	1.1	0.9 - 1.1	ppm	10000
CHLORIDE	2/3/2020	WVAWC-KANAWHA VALLEY DIST	7.1	7.1	MG/L	250
MAGNESIUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	6	6	MG/L	
SODIUM	2/3/2020	WVAWC-KANAWHA VALLEY DIST	6.2	6.2	MG/L	1000
SULFATE	2/3/2020	WVAWC-KANAWHA VALLEY DIST	36.2	36.2	MG/L	250
ZINC	2/3/2020	WVAWC-KANAWHA VALLEY DIST	0.064	0.064	MG/L	5

During the 2020 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2020				

There are no additional required health effects violation notices.

There are no additional required health effects notices.

This Consumer Confidence Report is not being mailed to each customer. A copy can be provided upon request by calling our office at 304-756-2141.