


EN 12150 - 1: 2012 Test Report

Production Details

Project No: 123458		Project Name: Dubai Marina Mall	
Batch No: 1005	Order No: N/A	Customer: N/A	
Item No: Test Piece	Nominal Thickness: 6mm	Nominal Width: 360mm	Nominal Height: 1100mm
Manufacturer: AGC Glass Europe		Glass Type: Clear Float	
Product: Planibel Clear		Manufacturers Batch No: 48A1554563	
Paint Batch No: N/A		Tempering Furnace: Cooltemper Super Jetstream 2540	

Size Tolerance and Thickness.

Width1: 360mm
Width2: 360mm
Height1: 1101mm
Height2: 1059mm
Left Diagonal: 1158mm
Right Diagonal: 1157mm
Size Tolerance: 1.00mm
Diag Tolerance: 1.00mm
Size Tol Result: PASS
Diag Tol Result: PASS
Actual Thickness: 5.82mm
Thickness Result: PASS



Hole 1

Nom Dia: N/A	Act Dia: N/A	Land: N/A	Pitch: N/A	C Land: N/A	Result: N/A
--------------	--------------	-----------	------------	-------------	-------------

Hole 2

Nom Dia: N/A	Act Dia: N/A	Land: N/A	Pitch: N/A	C Land: N/A	Result: N/A
--------------	--------------	-----------	------------	-------------	-------------

Hole 3

Nom Dia: N/A	Act Dia: N/A	Land: N/A	Pitch: N/A	C Land: N/A	Result: N/A
--------------	--------------	-----------	------------	-------------	-------------

Hole 4

Nom Dia: N/A	Act Dia: N/A	Land: N/A	Pitch: N/A	C Land: N/A	Result: N/A
--------------	--------------	-----------	------------	-------------	-------------

Hole 5


Nom Dia: N/A	Act Dia: N/A	Land: N/A	Pitch: N/A	C Land: N/A	Result: N/A
--------------	--------------	-----------	------------	-------------	-------------

Hole 6

Nom Dia: N/A	Act Dia: N/A	Land: N/A	Pitch: N/A	C Land: N/A	Result: N/A
--------------	--------------	-----------	------------	-------------	-------------

Distortion


Roller Pitch: 115mm
Roller Wave: 0.04mm
True Distortion: 120.98Dmdpt
Distortion Result: PASS



EN 12150 - 1: 2012 Test Report

Overall Bow


Width1: 0.1mm
Width2: 0.2mm
Height1: 0.9mm
Height2: 0.8mm
Diagonal: 1mm
Max Bow: 0.86mm/m
Overall Bow Result: PASS



Edge Lift

Width1: 0.09mm
Width2: 0.10mm
Height1: 0.07mm
Height2: 0.06mm
Max Edge Lift: 0.10mm


Edge Lift Result:
PASS



Mechanical Strength - 4 Point Proxy Bend Test.

Applied Force: 1296N
Max Deflection: 55mm

Mechanical Strength Result:
PASS



Mechanical Strength - GASP Test.

Angle: N/A psi: N/A kgf/cm²: N/A MPa: N/A GASP Result: N/A

Fragmentation


Glass Type: Float	Min Count: 40	Perimeter: 47	Central: 54
Count: 77.5	Count Result: PASS	Longest: 11mm	Longest Result: PASS

Comment

Within the comments section you can add anything you want with respect to each part of the overall test describing the issues found and possible courses of action to rectify.

EN 12150 - 1: 2012 Test Report

Summary



Authorised Signature

